

**AGENCY REQUEST FOR
AE SELECTION
SEPTEMBER 2016**

AGENCY: Department of Military Affairs

DMA CONTACT: LTC Todd F. Lundin, 608-242-3365, todd.lundin@wi.gov

DFD CONTACT: RJ Binau, (608) 267-6927, rj.binau@wisconsin.gov

LOCATION: Wisconsin Rapids, Wood

PROJECT REQUEST: Select an A/E consulting firm to provide pre-design, preliminary design and design report for WISCONSIN RAPIDS – FMS #14 Upgrade Exhaust Ventilation System.

PROJECT NUMBER: 16H3C

PROJECT DESCRIPTION: Upgrade industrial ventilation systems to bring into compliance with OSHA and NGB standards. Work will include necessary adjustments and/or tie in to the building’s HVAC system as well as upgrading the HVAC system to be controlled via a new DDC system to optimize ventilation and controls throughout the facility. Upgrade Local Exhaust ventilation systems (LEV) as recommended by Corps of Engineers (COE) exhaust flow rates. Upgrade battery charging room to comply with ventilation and spill requirements.

PROJECT JUSTIFICATION: WIARNG Industrial Hygiene office has identified these ventilation systems not meeting OSHA or NGB requirements. Exhaust ventilation system currently in place cannot safely handle the volume of fumes produced from vehicles while working. No DDC is available for the existing heating ventilation system.

BUDGET/SCHEDULE:

	Federal	State	Total
Construction	\$	\$0	\$
Design	\$	\$0	\$
DFD Mgmt.	\$	\$0	\$
Contingency	\$	\$0	\$
TOTAL	\$464,000	\$0	\$464,000

A/E Selection	SEP 2016
Design Report	FEB 2017
SBC Approval	MAR 2017
Bid Opening	JUNE 2017
Start Construction	AUGUST 2017
Substantial Completion	NOV 2017
Final Completion	DEC 2017

PREVIOUS ACTION: N/A